

# Evidence of Performance

Resistance to wind load  
Watertightness, Air permeability  
Operating forces, Load-bearing capacity of  
safety devices

Test Report 102 34194/1e (ITT)

Translation of Test Report 102 34194/1 dated 17 September 2007




Client **FIRAT PLASTIK VE KAUCUK A.S.**  
**Türkoba Koyü P.K.**  
**12 Büyükçekmece**

**Istanbul**  
**Turkey**

#### Base

EN 14351-1 : 2006-03  
Test standards:  
EN 1026 : 2000-06  
EN 1027 : 2000-06  
EN 12211 : 2000-06  
EN 12046-1 : 2003-11  
EN 14609 : 2004-03

#### Representation



Product	Single tilt and turn window
Designation	F7060
Overall dimensions (W x H)	750 mm x 1500 mm
Frame material	PVC-U / white
Special features	-/-

#### Instructions for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1 : 2006-03. For the sake of clarity it may be used as the basis for the ITT report summary by the manufacturer in the framework of the attestation of conformity procedure 3 as the basis for the manufacturer declaration.

#### Validity

The data and results refer solely to the tested and described specimen.

Subject to compliance with the relevant casement weights, the test results can be extrapolated for constructions of identical or smaller dimensions of the same design, type of rebate and similar format.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

#### Notes on publication

The Ift-Guidance Sheet "Conditions and Guidance for the Use of Ift test Documents" applies..

The cover sheet can be used as abstract.

#### Contents

The report contains a total of 9 pages.

#### Resistance to wind load – EN 12210



**Class C3/B3**

#### Watertightness – EN 12208



**Class 8A**

#### Air permeability – EN 12207



**Class 4**

#### Operating forces – EN 13115




**Class 1**

#### Load-bearing capacity of safety devices



**Requirement fulfilled**

Ift Rosenheim  
17 October 2007

  
Jörn Peter Lass, Dipl.-Ing. (FH)  
Head of Testing Department  
Ift Centre Windows & Facades

  
Benno Reichelt, Dipl.-Ing. (FH)  
Test engineer  
Ift Centre Windows & Facades



Ift Rosenheim GmbH  
Geschäftsführer:  
Dipl.-Ing. (FH) Ulrich Sieberath  
Dr. Jochen Pechi

Theodor-Gietl-Str. 7 - 9  
D-83026 Rosenheim  
Tel.: +49 (0)8331/281-0  
Fax: +49 (0)8331/281-290  
www.ift-rosenheim.de

Str. 83026 Rosenheim  
A.G. Traunstein, HRB 14763  
Sparkasse Rosenheim  
Kto. 3822  
BLZ 711 500 00

Notified Body Nr.: 0757  
Anerkante PLZ-Stelle: BAY 18  
  
DAP-PL 0000 00  
DAP-20 0000 00  
10A-20 10 00 00  
10A-20 10 00 00